



1000 NORTH 990-1200 EAST SEWER LINE REHABILITATION/REPLACEMENT

This information is hereby attached to and made part of the Bid Request Documents

Questions_1

7/12/17

1. There have been a few questions similar to the one below:

We offer a steam cured CIPP option for mainline sewers and would like to hear back from you on whether or not we can be considered as a third option or repair for the City of Logan.

City Response #1: Although there are other products available that have similar pipe characteristics and product lifespan, it was decided by the client not to include options for other pipe lining products on this project.

2. On the contract documents and specifications. The document makes a statement; "All surveying to be done and grades to be set by the City of Logan 435-716-9165. All survey requests to be given with at least 24 hr notice". We were questioning though if Logan City is still opening this project up for bid to other surveying companies as well, because I see that there is a slot for surveying under the bid schedule on item #4. It seems to me that Logan City might be opening this project for only the verification outlined in the specs. Is this correct? So is the bid for surveying only open for the couple verification objects listed under the specs?

City Response #2: There was found a conflict between the Special Provision of the Bid Documents and SURVEY AND CONSTRUCTION STAKING requirements on Sheet GN1 of the Construction Plans. It is the intent that the contractor hires a licensed professional surveyor to perform survey, construction stakeout, layout, and quantities verification.

OMIT FROM BID DOCUMENTS:
SPECIAL PROVISIONS NOTE #1