



## ENG 16046 400 NORTH RAISED PLANTER MEDIAN - Addendum 2A

April 27, 2017

This Addendum is hereby attached to and made part of the Bid Request Documents. Each firm submitting a bid shall acknowledge receipt of this addendum and acceptance of all conditions contained herein by including the addendum number and date on the Proposal Sheet of the bid package.

---

### ITEM 24 IRRIGATION SYSTEM - Clarification to Addendum 2, Items 8 and 9

8. Flow sensor to be installed on both irrigation systems for both medians (flow sensor will require a Rain Bird specification for the controller, specified by Parks department)
9. Each median irrigation system valve to be wired to automated irrigation control timer and constructed for permanent installation and secured for authorized maintenance access only.

**Two (2) Rain Bird ESP-LXME Controllers 6-Station Base**  
**Two (2) LXMMPED metal cabinet**

END OF ADDENDA