

# **Bridger Park Pickleball Courts**

## **Quality Control Inspection and Materials Testing**

### **Questions & Answers**

This information is hereby attached to and made part of the Proposal Request Documents

---

January 18, 2017

1. Does the list cover just the pickleball courts and none of the other site work?

Just the pickleball courts for the test area.

2. Line #8 concrete cylinder compressive strength at 120 hours. Normally we do pricing for the cylinders at a unit price not by hours. For post tensioning we will bid a set of seven 4"x 8" cylinder two for field cures and 5 for lab testing.

"Change Concrete Cylinder Compressive" to a unit price and provide 4 for each pad, total of 8 cylinders. (Revised Appendix A attached.)

3. Line #9 Final Tension inspection you show 1 each is this for all eight pads or for each pad. Are you planning to have all the pads placed at one time.

There are a total of two pads, they may be poured at different times and have different tension days.

APPENDIX A - Revised  
Proposed Fees  
Bridger Park Pickleball Courts  
Quality Control Inspection and Materials Testing

Item	Description	Rate	Quantity	Total
1	Soils/Asphalt Technician	\$	80 hrs	\$
2	Proctor	\$	3 each	\$
3	Field Density Testing	\$	120 each	\$
4	Sieve Analysis	\$	3 each	\$
5	Atterberg Limits	\$	3 each	\$
6	Concrete Inspector*	\$	100 hrs	\$
7	Concrete Technician	\$	50 hrs	\$
8	Concrete Cylinder Compressive	\$	8 each <del>120 hours</del>	\$
9	Final Tension Inspection	\$	1 each	\$
10	Tendon & Reinforcement Testing	\$	1 each	\$
15	Structural Steel Inspector**	\$	20 hrs	\$
16	Project Management and Reporting	\$	____ hrs	\$
17	Other:	\$		\$

Total Estimated Proposed Cost	\$
-------------------------------	----

\*Must be licensed as a Building Inspector with the Department of Professional Licensing (DOPL)

\*\*Must be Certified Welding Inspector with AWS and Licensed as a Building Inspector with DOPL

Company Name \_\_\_\_\_

Authorized by:

Name \_\_\_\_\_

Signature \_\_\_\_\_

Email Address \_\_\_\_\_