



PARKS & RECREATION

## LOGAN RIVER TRAIL: PEDESTRIAL BRIDGE AND PEDESTRIAN CROSSWALK

### ADDENDUM #1

July 20, 2017

This Addendum is hereby attached to and made part of the Bid Request Documents. Each firm submitting a bid shall acknowledge receipt of this addendum and acceptance of all conditions contained herein by including the addendum number and date on the Proposal Sheet of the bid package.

---

#### Drawings – Sheet S100 Additions

1. The bridge width is 10'-0" between the railing.
2. The bridge design shall incorporate horizontal pedestrian railing and meet 4" sphere requirements.

END OF ADDENDA