

200 NORTH & 400 NORTH SEWER IMPROVEMENTS QUESTIONS & ANSWERS

April 1, 2024
(Questions previously posted)

1. Will UDOT require restricted construction times?
 - A. Yes – See additional Special provisions and Conditional access permit- full day work will be allowed as long as one lane in each direction remains open with an approved by UDOT traffic control plan. Night work must be done from Main to 150 W on 200 N, near the 600 W intersection and any work on Main St.
2. Will UDOT allow Logan City approved backfill.
 - A. –Yes - Flowable fill is not required however, if flowable fill is desired for backfill, note that it will only be allowed below the pavement section of HMA and UTBC depths specified in the detail.
3. Are there any special lane closure requirements from UDOT?
 - A. UDOTs standard lane closure requirements will apply.
4. Will Logan City provide a hydrant meter-
 - A. Yes
5. Which manholes are the 60” vs 48”

200N	
MH	Diameter
SeMH00523	48
SeMH00257	48
SeMH00258	48
SeMH02300	48
SeMH00188	48
SeMH02301	48
SeMH02302	48
SeMH00193	48
SeMH02313	48
SeMH00724	48
SeMH03235	48
SeMH02314	48
SeMH00662	48

400N	
MH	Diameter
SeMH01815	60
SeMH02328	48
SeMH02330	60
SeMH02331	48
SeMH02332	60
SeMH02333	48
SeMH03429	48
SeMH02334	48
SeMH00104	48
SeMH00103	48
SeMH00102	48
SeMH02370	0
SeMH01034	48

SeMH02321	48	SeMH00142	60
		SeMH02071	48
		SeMH00111	48
		SeMH00113	48
		SeMH00112	60

6. Would the City accept Raven 405 Lining as an approved equal. For the Spectrashield liner?

A. No, not at this time.