

2019 Manhole and Valve Collars Adjustments and Repairs

Questions & Answers

This information is hereby attached to and made part of the Request for Bid documents

February 19, 2019

Q1- Will we be required to collar the utilities in these main intersections? (Center Street/100 East, 100 North/100 East, and 200 North/100 East)

A1- Yes, if they do not have existing leveled collars.

Q2- It appears that some of the utilities have existing concrete collars on them already. Will we be removing and replacing them?

A2 – Anything with an existing concrete collar that is not more than an inch low may be left as is (this applies throughout the project). 100 east had most of its collars fixed a few years back; this project is to finish the ones left undone.