

# Addendum No. 1 South Main Street Sidewalk Connection

This Addendum is hereby attached to and made part of the Bid Request Documents. Each firm submitting a bid shall acknowledge receipt of this addendum and acceptance of all conditions contained herein by including the addendum number and date on the Proposal sheet of the bid package.

---

January 7, 2019

Review by Logan City resulted in the following revisions to the work.

## **CONSTRUCTION PLANS**

### **SHEET GS102**

#### **General Utility Notes**

Added Note 13: "All water lines 4 inches or larger shall have mechanical joint restraints. Contractor shall submit to Logan City for review."

## **BID DOCUMENTS AND CONTRACT**

### **GENERAL CONDITIONS, SPECIAL PROVISIONS, AND SUPPLEMENTAL SPECIFICATIONS**

#### **Special Provisions**

Modified Special Provision 9 (page 40 of 51). Changed mandatory completion date of work within UDOT Right of Way from May 31, 2019 to May 15, 2019.

## **CONTRACT FOR CONSTRUCTION**

### **Article 4- Contract Times**

Modify contract Article 4.02.A (page 25 of 51). Changed mandatory completion date of work within the UDOT Right of Way from May 31, 2019 to May 15, 2019.

End of Addendum